

Duanesburg Central School District
 Elementary School
 Lead Water Testing Results As of 12-22-16

Sample Number	Location	Source	Parts Per Billion	Condition	Date	30 Second Draw	Date2	Remediation Plan	Replacement Result	Classroom Teacher
001	Room 112	Standard Hand Sink	4.7	Pass	9/19/2016					Minute
002	Room 112	Water Fountain	17	Failed	9/19/2016	2.8	10-14-16	Replace Fixture and Valves		Minute
003	Room 112	Toilet Room Sink	5.2	Pass	9/19/2016					Minute
004	Room 111	Toilet Room Sink	7.6	Pass	9/19/2016					Johnson
005	Room 111	Drinking Fountain	6.6	Pass	9/19/2016					Johnson
006	Room 111	Counter Sink	4.2	Pass	9/19/2016					Johnson
007	Room 307	Custodial Slop Sink in closet	29	Failed	9/19/2016	3.1	10-14-16	Replace Fixture and Valves		
008	Kitchen	Kitchen Sink	8.5	Pass	9/19/2016					
009	Kitchen	Kitchen Sink	7.0	Pass	9/19/2016					
010	Kitchen	Steam Pot - Sink	24	Failed	9/19/2016	1.5	10-14-16	Replace Fixture and Valves		
011	Kitchen	Toilet Room Sink	14	Pass	9/19/2016					
012	Kitchen	Dishwasher Spray Hose	3.1	Pass	9/19/2016					
013	Cafeteria	Drinking Fountain	1.7	Pass	9/19/2016					
014	Kitchen	Bathroom Sink & Outside Spigot	270	Failed	9/19/2016	1.5	10-14-16	Abandon Unit and Cap Off		
015	Room 109	Toilet Room Sink	3.8	Pass	9/19/2016					Waltz
016	Hallway near Cafeteria	Bottle Filler	< 1.0	Pass	9/19/2016					
017	Room 117b	Girls Hand Sink in Toilet Room	1.1	Pass	9/19/2016					
018	Room 117b	Girls Hand Sink in Toilet Room	< 1.0	Pass	9/19/2016					
019	Room 117b	Girls Hand Sink in Toilet Room	< 1.0	Pass	9/19/2016					
020	Room 117A	Boys Hand Sink in Toilet Room	< 1.0	Pass	9/19/2016					
021	Room 117A	Boys Hand Sink in Toilet Room	< 1.0	Pass	9/19/2016					
022	Room 117A	Boys Hand Sink in Toilet Room near Cafe	< 1.0	Pass	9/19/2016					
023	Room 118	Toilet Room Sink	1.0	Pass	9/19/2016					Waltz
024	Room 108	Toilet Room Sink	1.6	Pass	9/19/2016					Stetcher
025	Room 107 - Room 108 Shared Space	Sink	25	Failed	9/19/2016	0.86	10-14-16	Replace Fixture and Valves		Stryker & Stetcher
026	Room 107 - Room 108 Shared Space	Sink	23	Failed	9/19/2016	1.2	10-14-16	Replace Fixture and Valves		Stryker & Stetcher
027	Room 107	Toilet Room Sink	< 1.0	Pass	9/19/2016					Stryker
028	119M - Between Rooms 118 and 119	Counter Sink	13	Pass	9/19/2016					Durrant & Walsh
029	Room 118 & Room 119 Shared Space	Sink (Nearest Durrant's Room)	17	Failed	9/19/2016	0.45	10-14-16	Replace Fixture and Valves		Durrant & Walsh
030	Room 119	Sink in Toilet room	1.6	Pass	9/19/2016					Durrant
031	Staff Toilet Room	Toilet Room Sink	2.3	Pass	9/19/2016					
033	Room 106 Nurse	Toilet Room Sink	4.1	Pass	9/19/2016					Lounsbury
034	Faculty Room 127	Counter Sink	8.7	Pass	9/19/2016					
035	Custodial Closet	Slop Sink	44	Failed	9/19/2016	0.08	10-14-16	Replace Fixture and Valves		
036	Room 309 Closet	Sink (Not in use)	270	Failed	9/19/2016	X	X	Abandon Unit and Cap Off		Benjamin
037	Room 309	Sink	20	Failed	9/19/2016	19.5	10-14-16	Post Signage noting "Not Potable Water"		Benjamin
038	Room 311	Fountain & Sink Combo	17	Failed	9/19/2016	4.4	10-14-16	Replace Fixture and Abandon Fountain with Cap		McCabe
039	Room 312	Fountain & Sink Combo	20	Failed	9/19/2016	4.3	10-14-16	Replace Fixture and Abandon Fountain with Cap		Molyneau
040	Room 314	Fountain & Sink Combo	16	Failed	9/19/2016	5.1	10-14-16	Replace Fixture and Abandon Fountain with Cap		Goodwin
041	Room 315	Fountain & Sink Combo	39	Failed	9/19/2016	3.6	10-14-16	Replace Fixture and Abandon Fountain with Cap		Lane
042	Room 316	Water Fountain	10	Pass	9/19/2016					Lyons

